

117 De L'Eglise, St-Sauveur, Que., Canada, J0R 1R4
 Tel. : 514-236-5112 - Tel. : 1-877-821-2500


Fax : 450-227-4295

E-Mail: info@electrobreeze.com

Web site: <http://www.electrobreeze.com>

Instruction Installation and maintenance

This unit is the most efficient environmentally friendly filter or air cleaner on the market. Properly installed, it will provide complete satisfaction in the removal of air pollutants such as pollens, viruses and other living organisms.




A Fresh Breeze of Clean Air

Instructions:

1. Turn off power to the air handler
2. Remove the existing filter.
3. All forced-air systems have an internal 24 volt AC Class 2 power source to which this electronic Electro Air Cleaner may be connected without overloading other circuits. Before connecting your Electro Air Cleaner, you must identify the 24 volt AC power source.

4. After locating the 24 VAC power supply, connect the leads of the power cord as per



our electrical wiring diagram.

5. Alternatively, you may choose to use a 110/24 VAC Class 2 plug in adaptor. This adaptor is available at a very low cost at your dealer or directly at Electro Breeze Air Cleaner Ltd.
6. All electrical work should be performed by a qualified electrician.
7. Slide the Electro Air Cleaner into the filter slot and plug the power cord into the power head. (as shown below)

To replace collector cushion pad

1. Turn off the power on the air handler.
2. Open the air handler filter access door.
3. Unplug the 24 volt power-cord from power head.
4. Remove the Electro Breeze Air Cleaner.
5. Clean heavy accumulated dust with a vacuum on the outside screen.
6. Open the air Cleaner and remove the old Collector Cushion Pad and discard it into a garbage bag.
7. Replace with a new collector cushion pad by sliding the electrode into the color tubing inside the cushion.
8. Close the air cleaner and plug the 24 volt power cord into the power head.
9. Restore the air handler power.
10. You may hear some snap, crack noise at the beginning... this is normal because of variation in humidity and temperature, this noise should cease after a few hours of operation. If the arcing noise persists, consult your Electro Breeze Air Cleaner dealer.

Periodical operation maintenance

Your collector cushion pad should last from two(2) to four(4) months, depending on the dust application. For maximum effectiveness of the Electro Breeze Air Cleaner, we recommend that the fan control on the thermostat be in the position "ON".

Warning

Failure to change the collector cushion pad on a regular basis will result in a reduction of air flow through the air handler system. This can cause short cycling of your air handler system and may cause damage to your equipment.

