



# Certificate of Compliance

**Certificate:** 1381363

**Master Contract:** 218223

**Project:** 1381363

**Date Issued:** February 5, 2003

**Issued to:** Electro Breeze ltee  
117 De l'Église  
St-Sauveur, Qc JOR 1R4  
CANADA

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'*



**Issued by:**

  
Sylvain Gagnon, T.P.

**Authorized by:**

  
Alain Ste-Marie  
Operations Manager

## PRODUCTS

CLASS 1211 01 - AIR CLEANERS - Electrostatic

CLASS 1211 81 - AIR CLEANERS - Electrostatic - Certified TO U.S. STANDARDS

Electronic Air Filter, Models Electro 124- 224, rated 24V ac, 1.5 W.

### Note:

- The subject product is only for installation in furnace or air conditioner according to the manufacturer's instruction.
- The units must be powered from a Certified safety extra low voltage class 2 supply.

## APPLICABLE REQUIREMENTS

CSA Std C22.2 No 187-M1986  
ANSI/UL Std No 867 (4th Ed.)

- Electrostatic Air Cleaners
- Electrostatic Air Cleaners

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.

DOD 507WD 2002/04/30